

Water Audit Level 1 Validation – Review Document

Audit Information:

Utility: Brawley

PWS ID: 1310001

System Type: Potable

Audit Period: Calendar 2017

Validation Date: 9/17/2018

Utility Representation: Rodolfo Nunez, Juan Antunez, Rosa Ramiraz

Call Time: 12:00 pm

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 61 Data Validity Band (Level): Band III (51-70)

Real Loss: 40.21 (gal/conn/day)

Apparent Loss: 20.34 (gal/conn/day)

Non-revenue water as percent of cost of operating system: 2.9%

Certification Statement by Validator

7 and the California Water Code Section 10608.34. This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. oxtimes

Validator Information:

Water Audit Validator: Larry Lewison

Validator Qualifications: Contractor for California Water Loss TAP

2017 AWWA Water Audit Level 1 Validation

Water System Name: City of Brawley

Water System ID Number: 1310001

Water Audit Period:2017

Water Audit & Water Loss Improvement Steps:

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit: Staff trained in last water loss audit, Commercial meters are being added, Effluent meter keeps calibrated.

Certification Statement by Utility Executive:

in their manual, Water Audits and Loss Control Programs, Manual M36, Fourth Edition and in the Free Water Audit Software version 5. Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water

Rodolfo Nunez

Executive Name (Print)

water System Supervisor

Executive Position

9/18/2018

Date